

REPAIR

EDWARD LUI (512) 761-6476 / (512) 267-8639 FEBRUARY 27, 2013
Proposal Submitted to: Phone Date

125 VILLAGE PARK, GEORGETOWN TERRY SC0262-13
Street Job Name Serviced By:

LEAK REPAIR: Work needed to make watertight existing leaks shown as follows:



Location of Repairs:

1. Shingles have blown off on back side of roof as shown in pictures.
2. Replace missing, torn, and broken shingles in area of repair. **\$650.00**

NOTE: Shingles will not match exactly due to fading but will be of the same color and not be offensive.

3. Seal shingles in area of repair to prevent blow off.
4. Clean up and haul away debris from repair.

Additional Work needed:

5. To reseal all loose shingles on the entire roof would cost **\$300.00**

NOTE; Shingles that are still in place are not intact as the seal strip is contaminated and loose. It's just a matter of time until loose shingle tabs blow off. Every shingle on the entire house will need to be touched to make sure it is sealed properly.

6. Protect plumbing vent boots from the sun with a manufacturer's roofing paint and paint other vents to match.

WARRANTY: TWO YEARS, NO-LEAK LABOR WARRANTY on repairs.

TERMS: Warranty excludes acts of God such as tornados, hail, lightening, wind gust or straight line winds, foundation movement or repairs, rodent intrusions, tree limbs rubbing on roof, any damage to interior such as household goods, flooring, sheetrock, paint, etc. Not responsible for satellite receptions, please call ahead & schedule reset with satellite Co.

TOTAL AMOUNT OF REPAIR\$950.00

PLEASE MAKE CHECK PAYABLE TO: TERRY PARIS

THANK YOU!